

Opening Types and Ratings



Fire door openings are classified by their locations in a building. Location determines the length of exposure protection required, based on the potential fire hazard of that particular area. The opening classifications are shown below.

Description and Use	Door and Frame Rating
Openings that separate buildings or divide a single building into designated fire areas	180 minutes
Openings used in enclosures of vertical communication or egress through buildings (example: stairwells)	90 minutes
Door and frame assemblies that divide occupancies in a building	60 minutes
Opening in corridors where smoke and draft control is required	20minutes

FIRE DOOR FRAME, R39533, FIRE RATING: 2 HRS



FIRE DOOR FRAME, R39533, FIRE RATING: 3 HRS



FIRE DOOR LEAF, R39532, FIRE RATING: 2 HRS



FIRE DOOR LEAF, R39532, FIRE RATING: 3 HRS

